


LAMP PHOTOMETRIC REPORT

MODEL: 99POML30/WH		
POWER: 10W	VOLTAGE: 230V	WORKING VOLTAGE: 230V
MANUFACTURER: Elmark Industries JSC		

TOTAL FLUX: 1123.2 lm



$\gamma$	C0	C45	C90	C135	C180	C225	C270	C315	$\gamma$	$\Phi$ zone	$\Phi$ total	%
10	423.7	418.8	419.4	419.5	419.1	418.2	421.6	418.5	0- 10	40.48	40.48	3.6
20	389.2	390.1	391.6	392.7	390.9	388.9	388.0	388.7	10- 20	114.7	155.2	13.8
30	344.8	346.1	352.0	368.3	356.8	343.8	342.9	344.0	20- 30	171.4	326.5	29.1
40	289.5	291.6	301.9	306.8	309.2	287.1	286.6	287.8	30- 40	202.3	528.8	47.1
50	227.1	236.6	230.1	239.4	236.6	224.5	222.9	225.7	40- 50	202.7	731.5	65.1
60	166.9	164.1	163.0	169.5	168.2	159.5	157.1	161.1	50- 60	176.5	907.9	80.8
70	96.69	98.11	101.1	100.3	97.88	94.42	92.51	96.81	60- 70	128.2	1036	92.2
80	37.21	39.72	40.36	42.72	37.25	33.62	33.99	37.17	70- 80	70.74	1107	98.5
90	1.223	1.162	9.889	1.100	1.377	0.6272	0.5367	0.6619	80- 90	16.31	1123	100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG  
C Interval: 10.0DEG  
Test Speed: HIGH  
Temperature:25.3°C  
Operators:  
Test Date:28 November 2022

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 2.5DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.00.456  
Humidity:65.0%  
Test Distance:6.265m [K=1.0000]  
Remarks:

```

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

```

```

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

```